

CITY OF WEYAUWEGA  
PUBLIC WORKS COMMITTEE PROCEEDINGS  
DECEMBER 8, 2020

The Public Works Committee meeting was called to order by Chairman Bruce Goetsch at the Weyauwega Municipal Building Council Chambers at 6:30 pm. Roll call was taken. Members Present: Bruce Goetsch, Keith Najdowski and Dewey Stelzner. Also Present: Mayor Jack Spierings, City Administrator Jeremy Schroeder and Thad Majkowski with Cedar Corp.

*Motion Goetsch, second Najdowski, to approve the meeting minutes from November 10, 2020. Motion carried with all "ayes".*

**Citizen Appearances:** None

**Engineer Report:**

**Cedar Corp** – Thad Majkowski reported that the bid opening for the updates to the Wastewater Treatment System will be done on January 6<sup>th</sup> with the award going to Public Works on January 12<sup>th</sup> and Council on January 18<sup>th</sup>.

**A) Water System New Tower Update:** An update by Majkowski was included in the packet for all committee members to review. The construction company poured the cap on the tank foundation today.

- 1) Tank A20 Pay Request #3 for \$313,494.30:** *Motion Stelzner, second Najdowski, to approve pay Request #3 for \$313,494.30 contingent on receipt of wage rate verification and lien waivers. Motion carried with all "ayes".*
- 2) Change Order #1 for increase of \$7,550:** The change order is for the addition of the floor drain and hauling out of rock. *Motion Najdowski, second Stelzner, to approve change order #1 for an addition of \$7,550. Motion carried with all "ayes".*
- 3) Consideration of sanitary replacement/repair on High Street with water main work:** Majkowski brought televising maps from recent PLC televising. Discussion if funds are available to replace concerned or damaged sanitary as part of water main project. There is a considerable slope from Clark to South – no visible leaks but there are a couple of cracks. Manhole 272 is missing bottom of manhole as it has deteriorated. It was suggested to raise and replace bottom. High Street west from Emerald has some concern with a cracked pipe. Could potentially dig down and replace a 5' section. Any more would require road paving. There are considerable roots and a longitudinal crack. There are several options for potential repair. High Street east of Emerald has considerable roots. The construction contract is being finalized so now is the time to discuss these issues.
- 4) Design Standards Update:** The committee reviewed the updated design standards that were submitted. Anything listed in red is what is being changed from 2008. Kyle Young talked several times on the updates with Cedar Corp. *Motion Najdowski, second Stelzner, to approve the updated design standards. Motion carried with all "ayes".*

CITY OF WEYAUWEGA  
PUBLIC WORKS COMMITTEE PROCEEDINGS  
DECEMBER 8, 2020

**McMahon** - Nothing to report at this time.

**Star Dairy expansion discussion:** No one was present from Star Dairy. Goetsch had a question on catch basin placement. Majkowski stated sanitary sewer isn't as deep as storm sewer. He is concerned and would like to see more concrete plans from them. Majkowski would recommend steel casing to protect pipe. Kyle Young had a concern about milk spillage and containment so treatment plant doesn't get wiped out. Spierings asked about potential cost in addition to building costs for them to consider. Also concerns about snow plowing were discussed. Schroeder will reach out.

**Administrator/Public Works Supervisor Reports:** Nothing additional to report at this time.

**Set next meeting date/time:** The next committee meeting is scheduled for Tuesday, January 12, 2021 at 6:30 pm.

**Such Other Matters as Authorized by Law:** None

*Motion Stelzner, second Najdowski, to adjourn at 7:05 pm. Motion carried with all "ayes".*

**Recommendations to Council:**

1. Recommend to approve Pay Request #3 for \$313,494.30 contingent on receipt of wage rate verification and lien waivers.
2. Recommend to approve Change Order #1 for an addition of \$7,550.
3. Recommend to approve the updated design standards.

Jeremy Schroeder  
City Administrator